

Don & Low Ltd Nonwovens

Glamis Road
Forfar
Angus DD8 1EY

Tel: 01307 452600 Fax: 01307 452610
e-mail: nonwovens@donlow.co.uk
website: www.donlow.co.uk



Agrément Certificate

96/3220

Product Sheet 1

DON & LOW ROOF LININGS

DALTEX ROOFSHIELD FOR USE IN WARM NON-VENTILATED AND COLD VENTILATED ROOFS

This Agrément Certificate Product Sheet⁽¹⁾ relates to Daltex Roofshield⁽²⁾, a roof lining for use in warm non-ventilated and cold ventilated pitched roofs (for use in energy efficient non-ventilated cold pitched roofs, see Agrément Certificate 99/3648).

(1) Hereinafter referred to as 'Certificate'.

(2) Daltex Roofshield is a registered trademark of Don & Low Limited.

CERTIFICATION INCLUDES:

- factors relating to compliance with Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- design considerations
- installation guidance
- regular surveillance of production
- formal three-yearly review.



KEY FACTORS ASSESSED

Weathertightness – as part of a complete roof, the product will resist the passage of water and wind-blown snow and dust into the interior of the building (see section 6).

Risk of condensation – the product is regarded as an air permeable and a low water vapour resistance (Type LR) underlay and can be used as part of a warm non-ventilated and cold ventilated pitched roof system (see section 7).

Wind loading – when installed on appropriately spaced battens the product's physical properties are deemed adequate to resist the wind loads imposed on the underlay. The product will reduce the wind uplift forces acting on the roof covering (see section 8).

Strength – the product has adequate strength to resist the loads associated with installation of the roof (see section 9).

Durability – under the normal conditions found in a roof space, the product will have a service life comparable to a traditional roof tile underlay (see section 12).

The BBA has awarded this Certificate to the company named above for the product described herein. This product has been assessed by the BBA as being fit for its intended use provided it is installed, used and maintained as set out in this Certificate.

On behalf of the British Board of Agrément

Date of Ninth issue: 27 February 2015

Originally certificated on 9 February 1996

John Albon
Head of Approvals — Construction products

Claire Curtis-Thomas
Chief Executive

The BBA is a UKAS accredited certification body — Number 113.

The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at www.bbacerts.co.uk

British Board of Agrément

Bucknalls Lane
Watford
Herts WD25 9BA

©2015

tel: 01923 665300
fax: 01923 665301
clientservices@bba.star.co.uk
www.bbacerts.co.uk

Regulations

In the opinion of the BBA, Daltex Roofshield, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements of the following Building Regulations (the presence of a UK map indicates that the subject is related to the Building Regulations in the region or regions of the UK depicted):



The Building Regulations 2010 (England and Wales) (as amended)

Requirement: C2(b)

Resistance to moisture

Comment:

The product will contribute to a roof meeting this Requirement. See section 6.1 of this Certificate.

Regulation: 7

Materials and workmanship

Comment:

The product is an acceptable material. See section 12 and the *Installation* part of this Certificate.



The Building (Scotland) Regulations 2004 (as amended)

Regulation: 8(1)

Durability, workmanship and fitness of materials

Comment:

The use of the product satisfies the requirements of this Regulation. See section 12 and the *Installation* part of this Certificate.

Regulation: 9

Building standards applicable to construction

Standard: 3.10

Precipitation

Comment:

The product will contribute to a roof satisfying clauses 3.10.1⁽¹⁾⁽²⁾ and 3.10.8⁽¹⁾⁽²⁾ of this Standard. See section 6.1 of this Certificate.

Standard: 7.1(a)

Statement of sustainability

Comment:

The product can contribute to meeting the relevant requirements of Regulation 9, Standards 1 to 6 and therefore will contribute to a construction meeting a bronze level of sustainability as defined in this Standard.

Regulation: 12

Building standards applicable to conversions

Comment:

All comments given for this product under Regulation 9, Standards 1 to 6 also apply to this Regulation with reference to clause 0.12.1⁽¹⁾⁽²⁾ and Schedule 6⁽¹⁾⁽²⁾.

(1) Technical Handbook (Domestic).

(2) Technical Handbook (Non-Domestic).



The Building Regulations (Northern Ireland) 2012

Regulation: 23(a)(i)(iii)(b)(i) **Fitness of materials and workmanship**

Comment:

The product is an acceptable material. See section 12 and the *Installation* part of this Certificate.

Regulation: 28(b)

Resistance to moisture and weather

Comment:

The product will contribute to a roof satisfying this Regulation. See section 6.1 of this Certificate.

Construction (Design and Management) Regulations 2007

Construction (Design and Management) Regulations (Northern Ireland) 2007

Information in this Certificate may assist the client, CDM co-ordinator, designer and contractors to address their obligations under these Regulations.

See section:

1 *Description* and 14 *General* (14.6) of this Certificate.

Additional Information

NHBC Standards 2014

NHBC accepts the use of Daltex Roofshield, provided it is installed, used and maintained in accordance with this Certificate, in relation to *NHBC Standards*, Chapter 7.2 *Pitched roofs*.

CE marking

The Certificate holder has taken the responsibility of CE marking the product in accordance with harmonised European Standard EN 13859-1 : 2014. An asterisk (*) appearing in this Certificate indicates that data shown are given in the manufacturer's Declaration of Performance.

Technical Specification

1 Description

Daltex Roofshield is a triple layer spun-bonded polypropylene breather membrane. The product has the nominal characteristics given in Table 1.

Table 1 Nominal characteristics

Characteristic (units)	Roofshield
Thickness (mm)	0.75
Mass per unit area* (g m^{-2})	185
Roll length* (m)	50/100
Roll width* (m)	1.0/1.5 ⁽¹⁾
Colour	
upper	green ⁽¹⁾
lower	white ⁽¹⁾
Tensile strength* ($\text{N}\cdot 50 \text{ mm}^{-1}$)	
longitudinal	390
transverse	230
Elongation* (%)	
longitudinal	55
transverse	75
Tear resistance* (N)	
longitudinal	230
transverse	275
Resistance to penetration of air* ($\text{m}^3/\text{m}^2\cdot\text{h}\cdot 50 \text{ Pa}^{-1}$)	34.4
Watertightness*	
unaged	W1
aged ⁽²⁾	W1
Water vapour transmission* (S_d)	0.013
Water vapour resistance ($\text{MN}\cdot\text{s g}^{-1}$)	0.065

(1) Other widths and colours are available.

(2) Aged in accordance with BS EN 13859-1 : 2014, Annex C.

2 Manufacture

2.1 The membrane is manufactured by a lamination of an air and water vapour permeable membrane between two layers of non-woven polypropylene spunbond to form a flexible sheet.

2.2 As part of the assessment and ongoing surveillance of product quality, the BBA has:

- agreed with the manufacturer the quality control procedures and product testing to be undertaken
- assessed and agreed the quality control operated over batches of incoming materials
- monitored the production process and verified that it is in accordance with the documented process
- evaluated the process for management of nonconformities
- checked that equipment has been properly tested and calibrated
- undertaken to carry out the above measures on a regular basis through a surveillance process, to verify that the specifications and quality control being operated by the manufacturer are being maintained.

2.3 The management system of the Certificate holder has been assessed and registered as meeting the requirements of BS EN ISO 9001 : 2008 by BSI (Certificate FM 45536).

2.4 The product is marketed in the UK by the A. Proctor Group, The Haugh, Blairgowrie, Perthshire, PH10 7ER, tel: 01250 872261 fax: 01250 872727, email: contact@proctorgroup.com, website: www.proctorgroup.com

3 Delivery and site handling

3.1 Rolls are delivered to site individually wrapped in polythene. A technical leaflet bearing the product name is included with each roll and the BBA logo including the number of this Certificate is shown on the leaflet.

3.2 The rolls should be stored flat or on end, on a smooth, clean, dry surface, under cover and protected from sunlight.

Assessment and Technical Investigations

The following is a summary of the assessment and technical investigations carried out on Daltex Roofshield.

Design Considerations

4 Use

4.1 Daltex Roofshield is satisfactory for use as a fully supported or unsupported underlay in tiled and slated pitched roofs constructed in accordance with the relevant clauses of BS 5534 : 2014.

4.2 The product can also be used in energy efficient non-ventilated cold pitched roof systems. This application is covered by Agrément Certificate 99/3648.

5 Practicability of installation

Installation can be readily carried out by slaters/tilers experienced with this type of product.

6 Weathertightness



6.1 The product is classified as Class W1* in accordance with BS EN 13859-1 : 2014. The product will resist the passage of water, wind-blown snow and dust into the interior of a building under all conditions to be found in a roof constructed in accordance with the relevant clauses of BS 5534 : 2014.

6.2 The product resists penetration of liquid water and consequently may be used as temporary waterproofing prior to the installation of slates or tiles. The period of such use should, however, be kept to a minimum particularly during periods of high UV exposure. See BBA Information Bulletin No 2 *Permeable Roof Tile Underlay — Guide to Good Site Practice*.

7 Risk of condensation

7.1 For design purposes, the product's water vapour resistance may be taken as not more than $0.1 \text{ MN}\cdot\text{s}\cdot\text{g}^{-1}$ and for roofs designed in accordance with BS 5534 : 2014 or BS 5250 : 2011, Annex H, it may be regarded as a Type LR membrane.

7.2 The product is also air permeable with a nominal value of $34.4 \text{ m}^3\cdot\text{h}^{-1}\cdot\text{m}^{-2}$ at 50 Pa pressure difference, allowing a significant additional mechanism for water vapour egress by convection.

7.3 In common with all roofs, care must be taken in the overall design and installation to minimise the risk of water vapour coming into contact with cold parts of the construction. Factors to be considered and minimised include moisture diffusion through the ceiling, infiltration through unsealed openings/penetrations in the ceiling and services evaporating or venting moisture into cold spaces.

7.4 The risk of condensation is highest in new-build construction during the first heating period, where there is high moisture loading due to wet trades, such as in-situ cast concrete slabs or plaster. The air permeability of the product will reduce this risk (see section 7.2). The risk of condensation diminishes as the building naturally dries out. See BBA Information Bulletin No 1 *Roof Tile Underlays in Cold Roofs during the Drying-out Period*.

Ceiling and insulation horizontal (cold roof)

7.5 Roofs designed and constructed in accordance with BS 5250 : 2011 will adequately limit the risk of interstitial condensation. Alternatively, see section 4.2.

Ceiling and insulation inclined (warm roof)

7.6 For roofs with an insulated ceiling, ventilation above or below the underlay will not be required provided that the passage of moisture by diffusion and by convection is controlled, eg, a continuous envelope of insulation with a high vapour resistance.

Ceiling and insulation partially inclined (warm roof and cold roof)

7.7 Where an insulated ceiling only spans part of the roof line, resulting cold roof spaces should be ventilated in accordance with BS 5250 : 2011, Annex H. Alternatively, see section 4.2.

8 Wind loading

8.1 Project design wind speeds for the roof in which the product is installed should be determined, and wind uplift forces calculated, in accordance with BS EN 1991-1-4 : 2005 and its UK National Annex.

Unsupported

8.2 The product is satisfactory for use in unsupported systems in the geographical wind zones given in Table 2, where a well-sealed ceiling is present and the roof has a ridge height of $\leq 15 \text{ m}$, a pitch between 12.5° and 75° , a site altitude $\leq 100 \text{ m}$ and where topography is not significant. For all other cases, the required uplift resistance should be determined using BS 5534 : 2014 and the Certificate holder's declared wind uplift resistances in Table 3.

Table 2 Zones of applicability of Roofshield according to BS 5534 : 2014, clause A.8 with battened laps and laps with counterbattens

Product	≤345 mm batten gauge	≤250 mm batten gauge	≤345 mm batten gauge with counterbatten ⁽¹⁾
Roofshield	Zones 1 to 3	Zones 1 to 5	Zones 1 to 5

Table 3 Declared wind uplift resistance Pa

Product	≤345 mm batten gauge ⁽³⁾	≤250 mm batten gauge ⁽²⁾⁽³⁾	≤345 mm batten gauge with counterbatten ⁽¹⁾⁽³⁾
Roofshield	1252	2574	2192

(1) This applies to any counterbatten ≥11 mm deep.

(2) Underlays with a wind uplift resistance at a 250 mm batten gauge that meet the minimum design wind pressure of 820 Pa for Zone 1 are deemed to satisfy the requirements for use at 100 mm batten gauge in all wind zones.

(3) Mean of test results.

Supported

8.3 The product, when fully supported, has adequate resistance to wind uplift forces.

8.4 The product may be used at any batten gauge in all wind zones when laid over nominally airtight sheet sarking, for example OSB, plywood, chipboard and insulation for warm-roof design. It may also be used in applications where slates are nailed directly onto sarking boards.

8.5 Sarking boards, such as square-edged butt jointed planks, are not considered to be airtight and the underlay is treated as unsupported. When used with slates nailed directly onto softwood sarking boards, the product is satisfactory for use in geographical wind zones 1 to 5 and will achieve a declared wind uplift resistance of 2974 Pa.

9 Strength

The product will resist the normal loads associated with installation of the roof.

10 Properties in relation to fire

10.1 When tested to EN ISO 11925-2 : 2002, the product achieved a Class D* classification in accordance with BS EN 13501-1 : 2007.

10.2 The product will have similar properties in relation to fire to those of traditional polyethylene roof tile underlays.

10.3 When the product is used unsupported, there is a risk that fire can spread if the material is accidentally ignited during maintenance works, eg by a roofer's or plumber's torch. As with all types of underlay, care should be taken during building and maintenance to avoid the material becoming ignited.

10.4 When the product is used in a fully supported situation, the reaction to fire will be determined by support.

11 Maintenance

As the product is confined within a roof structure and has suitable durability (see section 12), maintenance is not required. However, it must be ensured that damage occurring before enclosure is repaired (see section 16).

12 Durability



The product will be virtually unaffected by the normal conditions found in a roof space and will have a life comparable with that of a traditional roof tile underlay, provided it is not exposed to sunlight for long periods (see section 14.4). Advice regarding exposure can be obtained from the Certificate holder.

13 Reuse and recyclability

The product is made from polyolefins, which can be recycled.

Installation

14 General

14.1 Daltex Roofshield must be installed and fixed in accordance with the Marketing Company's instructions, provisions of this Certificate and the relevant recommendations of BS 5534 : 2014 and BS 8000-6 : 1990. Installation can be carried out under all conditions normal to roofing work.

14.2 The product is installed with the green side uppermost and lapped to shed water out and down the slope.

14.3 Overlaps must be provided with the minimum dimensions given in Table 4.

Table 4 Minimum overlaps

Roof pitch(°)	Horizontal lap (mm)		Vertical lap (mm)
	Not fully supported	Fully supported	
12.5 to 14	225	150	100
15 to 34	150	100	100
35+	100	75	100

14.4 Where possible, eaves guards should be used to protect the product from sunlight, and to direct water into the gutter.

14.5 Hips should be covered with a 600 mm wide strip of the product.

14.6 The product has a smooth surface with a low coefficient of friction and care should be taken when moving or standing on a wet surface covered with the product.

15 Procedure

Unsupported

15.1 The product, when installed unsupported, is fixed in the traditional method for roof tile underlays, ie draped between the rafters.

Fully supported

15.2 The product may be used over sarking boards of softwood, C4 grade chipboard, water-resistance grade plywood or water-resistant grade OSB and either with continuous insulation or insulation placed between the rafters.

15.3 The product is secured to the support with counterbattens at least 12 mm thick to create an air space between the product and the tiles for drainage and vapour dispersal. The counterbattens are fixed with corrosion-resistant staples or galvanized clout nails as appropriate. Tiling battens are secured to the counterbattens and rafters with appropriate fixings.

15.4 Care must be taken to minimise the risk of interstitial condensation as described in section 7.5, particularly for timber sarking which may be below the dew-point for extended periods during winter months.

Factory-fabricated roof panel

15.5 The product can be used in factory-fabricated roof panels which are assembled under factory-controlled conditions. However, these panels have not been assessed by the BBA and are therefore outside the scope of this Certificate.

16 Repair

Damage to the product can be repaired prior to the installation of the slates or tiles by replacement of the damaged areas, by patching and sealing correctly. Care should be taken to ensure that the watertightness of the roof is maintained.

17 Finishing

17.1 Detailing of abutments, verges and hips must be in accordance with the Certificate holder's instructions.

17.2 Tiling and slating must be carried out in accordance with the relevant clauses of BS 5534 : 2014, BS 8000-6 : 2013 and the Certificate holder's instructions, especially when using tightly-jointed slates or tiles.

Technical Investigations

18 Tests

18.1 An assessment was made of data to BS EN 13859-1 : 2014 in relation to:

- dimensions*
- mass per unit area*
- tensile strength and elongation*
- resistance to tear*
- dimensional stability*
- resistance to water penetration*
- resistance to artificial ageing*
- resistance to penetration of air*
- water vapour transmission*.

18.2 Tests were carried out to determine:

- slip resistance

- Mullen burst strength
- resistance to wind loads

in order to assess:

- safety during installation
- performance under typical service conditions
- robustness during installation
- properties when installed.

19 Investigations

19.1 The manufacturing process was evaluated, including the methods adopted for quality control, and details were obtained of the quality and compositions of materials used.

19.2 The condensation risk in warm roof constructions, and specifically those containing sarking boards, incorporating the product was examined.

19.3 Data on wet strength were examined.

19.4 An examination was made of independent data on the investigation of wind loads on the underlay/tile roof systems and data on behaviour of roof tile underlays under suction.

Bibliography

BS 5250 : 2011 *Code of practice for control of condensation in buildings*

BS 5534 : 2014 *Code of practice for slating and tiling (including shingles)*

BS 8000-6 : 2013 *Workmanship on building sites — Code of practice for slating and tiling of roofs and claddings*

BS EN 1991-1-4 : 2005 *Eurocode 1: Actions on structures — General actions — Wind actions*

NA to BS EN 1991-1-4 : 2005 *UK National Annex to Eurocode 1: Actions on structures — General actions — Wind actions*

BS EN 13501-1 : 2007 *Fire classification of construction products and building elements — Classification using test data from reaction to fire tests*

BS EN 13859-1 : 2010 *Flexible sheets for waterproofing — Definitions and characteristics of underlays — Underlays for discontinuous roofing*

BS EN ISO 9001 : 2008 *Quality management systems — Requirements*

Conditions of Certification

20 Conditions

20.1 This Certificate:

- relates only to the product/system that is named and described on the front page
- is issued only to the company, firm, organisation or person named on the front page — no other company, firm, organisation or person may hold or claim that this Certificate has been issued to them
- is valid only within the UK
- has to be read, considered and used as a whole document — it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- is subject to English Law.

20.2 Publications, documents, specifications, legislation, regulations, standards and the like referenced in this Certificate are those that were current and/or deemed relevant by the BBA at the date of issue or reissue of this Certificate.

20.3 This Certificate will remain valid for an unlimited period provided that the product/system and its manufacture and/or fabrication, including all related and relevant parts and processes thereof:

- are maintained at or above the levels which have been assessed and found to be satisfactory by the BBA
- continue to be checked as and when deemed appropriate by the BBA under arrangements that it will determine
- are reviewed by the BBA as and when it considers appropriate.

20.4 The BBA has used due skill, care and diligence in preparing this Certificate, but no warranty is provided.

20.5 In issuing this Certificate, the BBA is not responsible and is excluded from any liability to any company, firm, organisation or person, for any matters arising directly or indirectly from:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product/system or any other product/system
- the right of the Certificate holder to manufacture, supply, install, maintain or market the product/system
- actual installations of the product/system, including their nature, design, methods, performance, workmanship and maintenance
- any works and constructions in which the product/system is installed, including their nature, design, methods, performance, workmanship and maintenance
- any loss or damage, including personal injury, howsoever caused by the product/system, including its manufacture, supply, installation, use, maintenance and removal.
- any claims by the manufacturer relating to CE marking.

20.6 Any information relating to the manufacture, supply, installation, use, maintenance and removal of this product/system which is contained or referred to in this Certificate is the minimum required to be met when the product/system is manufactured, supplied, installed, used, maintained and removed. It does not purport in any way to restate the requirements of the Health and Safety at Work etc. Act 1974, or of any other statutory, common law or other duty which may exist at the date of issue or reissue of this Certificate; nor is conformity with such information to be taken as satisfying the requirements of the 1974 Act or of any statutory, common law or other duty of care.